

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-192652-01

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

Product(s): Building hardware - Controlled door closing devices - Requirements and test methods (refer to attached appendix for details and conditions)

Placed on the market under the name or trade mark of: EURO ART (UK) LTD
69 Staverton Road, London, NW2 5HA, UK

and produced in the manufacturing plant(s): SG-15097

Intended use: On fire and smoke compartmentation doors (to fulfil the self-closing requirements of such doors)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN 1154:1996/A1:2002/AC:2006

Under System 1 for the performances set out in this certificate are applied and that the performance of the construction product fulfils all the prescribed requirements for these performances.

This certificate first issued on **2019-12-12** and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performances of the declared essential characteristics, do not change, and the construction product, and the manufacturing conditions in the plant are not modified significantly, unless suspended or withdrawn by the product certification body.

The issued document and statement(s) herein makes reference only to a presumption of conformity in accordance with the CPR Regulations EU 305/2011 (as amended). However, it is the manufacturer's or their authorised representative's sole responsibility to affix the CE logo and, by doing so, confirms full compliance and conformity to all other European mandatory directives and regulations that may also apply.



Signature:

92654

Name:

Dipl.-Ing. Roland Heine

Date: 2019-12-12

Issue: 01

Position: Certification Manager



CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-192652-01

APPENDIX TO: Certificate of Constancy of Performance

Brand: Euroart
Model Ref: DC3024

Table A1. Mechanical test reports & Product classification for Door Closer from EURO ART (UK) LTD

Test Report	Model tested	Product Classification					
190121011SHF-BP-2	DC3024	3	8	4	1 ^a	1	4
				2			
Evaluated function: Concealed installation, Selectable Power Size 2 to 4, with latch control, Backcheck							

Table A3. Fire test report(s) for Door Closer from EURO ART (UK) LTD^b

Test Report	Model tested	Test Method	Fire resistance (minutes)	
			E - Integrity	I - Insulation
190409013SHF-002	DC3024	EN 1634-1:2014	260	22

Notes.

- Digit 4 grade "1" was based on the test result from fire resistance test (refer to Table A3). Door closers with adjustable closing force shall be capable of adjustment at least to Power Size 3.
- The door closer shall be installed in accordance with the installation instructions for the product(s).

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-192652-01

APPENDIX TO: Certificate of Constancy of Performance

Table A4. EN 1154 Annex ZA Related Information for Door Closer from EURO ART (UK) LTD

Product:	Controlled door closing devices DC3024	
Intended use:	On fire and smoke compartmentation doors (to fulfil the self-closing requirements of such doors) -Concealed installation	
Requirement/ characteristic	Standard clause	Result Summary
Self-closing	General (5.2.1)	Grade 3 (closing doors from at least 105° open)
	Closing moment (5.2.3)	Power size 2 to 4
	Opening moment (5.2.4)	Power size 2 to 4
	Efficiency (5.2.5)	Power size 2: More than 50% Power size 3: More than 55% Power size 4: More than 60%
	Closing time (5.2.6)	Pass
	Angles of operation (5.2.7)	Grade 3, 105°
	Overload performance (5.2.8)	Pass
	Temperature dependence (5.2.9)	Pass (-15°C to +40°C)
	Fluid leakage (5.2.10)	Pass
	Damage (5.2.11)	Pass
	Latch control (5.2.12)	Pass
	Backcheck (5.2.13)	Pass
	Delayed closing (5.2.14)	Not applicable
	Adjustable closing force (5.2.15)	Pass
	Zero position (5.2.16)	Not applicable
Durability of self-closing	Fire/smoke door suitability (5.2.18), Annex A	Grade 1, Suitable for use on fire/smoke doors (refer to Table A3).
	Durability (5.2.2)	500,000 test cycles
Dangerous substances	Corrosion resistance (5.2.2 5.2.17.1, 5.2.17.2)	Grade 4, Neutral Salt Spray (NSS) for 240 hours
	See Clause ZA.3	No dangerous substances declared for this product/ intended use

END OF DOCUMENT

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.