



Notified body No. 1121
Warrington Certification Limited, Holmesfield Road, Warrington, Cheshire, WA1 2DS, UK

Certificate of constancy of performance 1121-CPR-AD5186

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Euroart DC6025BC Overhead door closer

Intended use: For use on fire rated single leaf and double leaf doors STANDARD DOOR MOUNT PULL SIDE APPLICATION.

Essential characteristics	Performance	Harmonised technical specification
	Test Refs : 174314T, 174314T/P & 179372	
Self closing	1743141/F & 179372	
5.2.1 General		
5.2.2 Durability	500,000 test cycles	1
5.2.3 Closing moment	Pass size 2 to 5	
5.2.4 Opening moment	Pass size 2 to 5	EN 1154:1996/A1:2002/AC:2006
5.2.5 Efficiency	>50% size 2	
5.2.5 Efficiency	>65% size 5	
5.2.6 Closing time	Pass	
5.2.7 Angles of operation	Grade 4, 180°	
5.2.8 Overload performance	Pass	
5.2.9 Temperature dependence	-15°C to +40°C	
5.2.10 Fluid leakage	Pass	
5.2.11 Damage	Pass	
5.2.12 Latch control	Pass	
5.2.13 Back check (optional)	Pass	
5.2.14 Delayed closing	NPD	
(optional) 5.2.15 Adjustable closing force	Pass	-
(optional)	FdSS	
5.2.16 Zero position (double	NPD	
action door closers only)		
5.2.18 Fire/smoke door suitability	Pass	
Essential characteristics	Performance	Harmonised technical specification
Durability of Self Closing		op comesmen
5.2.2 Durability	500,000 test cycles	
5.2.17.1 corrosion	Grade 3 (96 hours)	EN 1154:1996/A1:2002/AC:2006
5.2.17.2 corrosion	Pass	
Dangerous Substances	Pass: the materials in the door closer	
Annex ZA3	do not contain or release any	
7 tt 5 / 2 / 10	dangerous substances in excess of	
	the maximum levels specified in	
	existing European material standards	
	or any national regulations	

Page 1 of 3





Certificate of constancy of performance 1121-CPR-AD5186

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Euroart DC6025BC Overhead door closer

Intended use: For use on fire rated single leaf and double leaf doors PARALLEL ARM APPLICATION.

Essential characteristics	Performance	Harmonised technical specification
Self closing		
5.2.1 General		
5.2.2 Durability	500,000 test cycles	
5.2.3 Closing moment	Pass size 2 to 4	
5.2.4 Opening moment	Pass size 2 to 4	
5.2.5 Efficiency	>50% size 2	
5.2.5 Efficiency	>60% size 4	
5.2.6 Closing time	Pass	
5.2.7 Angles of operation	Grade 4, 180°	
5.2.8 Overload performance	Pass	EN 1154:1996/A1:2002/AC:2006
5.2.9 Temperature dependence	-15°C to +40°C	EN 1154.1990/A1.2002/AC.2000
5.2.10 Fluid leakage	Pass	
5.2.11 Damage	Pass	
5.2.12 Latch control	NPD	
5.2.13 Back check (optional)	Pass	
5.2.14 Delayed closing	NPD	
(optional)		
5.2.15 Adjustable closing force	Pass	
(optional)		
5.2.16 Zero position (double	NPD	
action door closers only)		
5.2.18 Fire/smoke door	Pass	
suitability		
Essential characteristics	Performance	Harmonised technical
		specification
Durability of Self Closing		
5.2.2 Durability	500,000 test cycles	
5.2.17.1 corrosion	Grade 3 (96 hours)	
5.2.17.2 corrosion	Pass	EN 1154:1996/A1:2002/AC:2006
Dangerous Substances	Pass: the materials in the door closer	EN 1134.1390/A1.2002/A0.2000
Annex ZA3	do not contain or release any	
	dangerous substances in excess of	
	the maximum levels specified in	
	existing European material standards	
	or any national regulations	





Certificate of constancy of performance

1121-CPR-AD5186

produced for

EURO-ART (UK) LTD

1-Chain Caul Way, Rivers Docklands, Ashton on Ribale,
Preston. Lancs. PR2 2YL

and produced in the manufacturing plant

K/004

This is coded format and the information is held by the Notified Body.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 1154:1996/A1:2002/AC:2006

under system 1 of AVCP are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on **03/12/14** and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

Paul Duggan
Certification Manager
Warrington Certification Ltd

